

JACKSON COUNTY FIRE DISTRICT 5
SEISMIC REHABILITATION PROJECT
STATION 4
ADDENDUM 3

This addendum forms a part of the Contract Documents and modifies the original Documents dated **September 26, 2022**, as noted below. Acknowledge receipt of this addendum in the space provided on the Official Bid Form. Failure to do so may subject the Bidder to disqualification.

QUESTIONS AND CLARIFICATIONS

Question: Do all windows get an MDF sill?

Answer: Yes, all windows to have an MDF sill.

Question: Is the wall cap going on the new wall (2017) of 2/A2.01?

Answer: Yes, wall cap to be located on new low wall at mezzanine, as indicated on 2/A2.01.

Question: Is there a species or grade for the plywood?

Answer: Use Grade AC for Apparatus Wainscot. Other plywood per Structural.

NOTICE

The deadline for questions has expired. Any additional questions will not be answered.

END OF ADDENDUM 3